

Facility Summary in Silver Bow County in the City of Butte

Location: ACADIA MONTANA
55 Basin Creek Rd
Butte, MT 59701-9704 Silver Bow

System Facility ID:47-00458

Facility Code: 28332
Last Inspected On: 04/19/2022
Operating Permit Renewal Date: 09/21/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Kids Behavioral Health	4064944183
Operator Contact:	Bill English;Leon Huizinga;Todd Skartved	4064966329;4064984550;4067822143

Owner/Operator: Kids Behavioral Health

- Bill English, UST Class A Operator
- Bill English, UST Class B Global Operator
- Leon Huizinga, UST Class A Operator
- Leon Huizinga, UST Class B Operator
- Todd Skartved, UST Class A Operator

Tank Code	01	Tank Age	35	Tank Installed Date	06/22/1987	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Copper	Overfill Types	Flapper Valve
Tag Number	3974	Spill Test Date	04/19/2022	Piping Installed Date		Tank Construction		Piping Construction	Secondary Containment Chase	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/19/2022	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	2000	ATG Test Date	04/19/2022	Line Tightness Test Date	08/12/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	3-Year Line Tightness Test	Energy Act	No
		Overfill Test Date	04/19/2022			ATG Type	Veeder Root/TLS-300				

Facility Summary in Silver Bow County in the City of Butte

Location: BUTTE MAIN CENTRAL OFFICE
200 W Broadway St
Butte, MT 59701-9226 Silver Bow

System Facility ID:56-14034

Facility Code: 30690
Last Inspected On: 10/12/2022
Operating Permit Renewal Date: 04/18/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Century Link Communication	5016808141
-------------------------	----------------------------	------------

Operator Contact: Stephanie Miller

5016808141

Owner/Operator: Century Link Communication

Stephanie Miller, UST Class A Operator
Stephanie Miller, UST Class B Global Operator

Tank Code	01	Tank Age	20	Tank Installed Date	10/02/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4732	Spill Test Date	02/27/2020	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	02/27/2020	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	U.S. Suction	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	3-Year Line Tightness Test	Vapor Recovery	No
Capacity	2500	ATG Test Date		Line Tightness Test Date	02/27/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Silver Bow County in the City of Butte

Location: BUTTE SCHOOL DIST 1 BUS BARN
1220 E Front St
Butte, MT 59701-2936 Silver Bow

Facility Code: 28355
Last Inspected On: 09/29/2022
System Facility ID:47-01980
Operating Permit Renewal Date: 01/31/2026

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: School Dist 1 Butte

Operator Contact: Bill English;Jed Johnson;Leonard Diaz;Todd Skartved

4064984550;4067822143

Owner/Operator: School Dist 1 Butte

Bill English, UST Class A Operator
Bill English, UST Class B Global Operator
Jed Johnson, UST Class A Operator
Jed Johnson, UST Class B Global Operator
Leonard Diaz, UST Class A Operator
Leonard Diaz, UST Class B Operator
Todd Skartved, UST Class A Operator
Todd Skartved, UST Class B Global Operator

Tank Code	03	Tank Age	30	Tank Installed Date	08/01/1992	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1892	Spill Test Date	09/29/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	09/29/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/29/2022			ATG Type	Gilbarco/EMC Basic;Gilbarco-Veeder Root/EMC Basic				

Facility Summary in Silver Bow County in the City of Butte

Location: CENEX ZIP TRIP #72 2801 Harrison Ave Butte, MT 59701-3715 Silver Bow	System Facility ID:47-05148	Facility Code: 28404 Last Inspected On: 11/06/2020 Operating Permit Renewal Date: 12/26/2023
Note: Inspection is due 90 days before the Operating Permit Renewal Date.		

Owner Operator Contact:	CHS Inc Spokane Valley	5095357701
Operator Contact:	Deb Morris;Jim Alford;Roy Morris;Sean Hurley	4067824255;5095357701;5095367418

Owner/Operator:	CHS Inc Spokane Valley
	Deb Morris, UST Class A Operator
	Deb Morris, UST Class B Operator
	Isaac Durnford, UST Class B Operator
	Jim Alford, UST Class A Operator
	Jim Alford, UST Class B Global Operator
	Karina Serrano, UST Class B Global Operator
	Roy Morris, UST Class A Operator
	Sean Hurley, UST Class A Operator

Tank Code	08	Tank Age	32	Tank Installed Date	03/19/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1707	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	05/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	09	Tank Age	32	Tank Installed Date	03/19/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1708	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	05/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	10	Tank Age	32	Tank Installed Date	03/19/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1709	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	11	Tank Age	32	Tank Installed Date	03/19/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1710	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Tank Code	12	Tank Age	32	Tank Installed Date	03/19/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	1711	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date	05/19/2020	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: CENEX ZIP TRIP #73
848 W Park St
Butte, MT 59701-9066 Silver Bow

System Facility ID:47-00386

Facility Code: 28330
Last Inspected On: 05/12/2022
Operating Permit Renewal Date: 05/16/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: CHS Inc Spokane Valley 5095357701

Operator Contact: Jim Alford;Roy Morris;Sean Hurley 4067824255;5095357701;5095367418

Owner/Operator: CHS Inc Spokane Valley

Jim Alford, UST Class A Operator
Jim Alford, UST Class B Global Operator
Luci Tuttle, UST Class B Operator
Roy Morris, UST Class A Operator
Sean Hurley, UST Class A Operator

Tank Code	05	Tank Age	24	Tank Installed Date	09/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4425	Spill Test Date	10/05/2021	Piping Installed Date	05/15/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/27/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/22/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/04/2022	Line Tightness Test Date	01/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes

		Overfill Test Date	10/05/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	06	Tank Age	24	Tank Installed Date	09/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4426	Spill Test Date	10/05/2021	Piping Installed Date	05/15/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/27/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/22/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/04/2022	Line Tightness Test Date	01/21/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/05/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	07	Tank Age	24	Tank Installed Date	09/01/1998	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4427	Spill Test Date	10/05/2021	Piping Installed Date	05/15/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/27/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/22/2019	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	5000	ATG Test Date	08/04/2022	Line Tightness Test Date	01/20/2022	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date	10/05/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

Facility Summary in Silver Bow County in the City of Butte

Location: DETENTION CENTER
155 W Quartz St
Butte, MT 59701-9200 Silver Bow

System Facility ID:56-14119

Facility Code: 30760
Last Inspected On: 01/28/2020
Operating Permit Renewal Date: 05/27/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte Silver Bow County

4064976569

Operator Contact: Jed Johnson;John Stajcar

4064976569

Owner/Operator: Butte Silver Bow County

Jed Johnson, UST Class A Operator
Jed Johnson, UST Class B Global Operator
John Stajcar, UST Class A Operator
John Stajcar, UST Class B Global Operator

Tank Code	01	Tank Age	17	Tank Installed Date	01/31/2005	Tank Material	Steel Clad	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	5006	Spill Test Date		Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	01/28/2020	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	1000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Silver Bow County in the City of Butte

Location: FED EX DISTRIBUTION
119771 Rick Jones Way
Butte, MT 59750 Silver Bow

Facility Code: 30904
Last Inspected On: 10/28/2020
System Facility ID:60-15178
Operating Permit Renewal Date: 04/12/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Arc Febttmt 001 LLC

2154493600

Operator Contact: Chong Lee;Greg Peters

4067824176;4086543112

Owner/Operator: Arc Febttmt 001 LLC

Chong Lee, UST Class A Operator
Greg Peters, UST Class A Operator
Greg Peters, UST Class B Operator

Tank Code	01									Flapper
-----------	----	--	--	--	--	--	--	--	--	---------

		Tank Age	11	Tank Installed Date	03/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Valve;High Level Alarm
Tag Number	5286	Spill Test Date		Piping Installed Date	12/20/2010	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/28/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	10/28/2020	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	20000	ATG Test Date		Line Tightness Test Date	07/10/2020	Secondary Tank Leak Detection	Automatic Tank Gauging 0.2	Secondary Pipe Detection	ELLD 0.2	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350;Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/				

Facility Summary in Silver Bow County in the City of Butte

Location: HOLLOW CONSTRUCTION
404 W Greenwood Ave
Butte, MT 59701-2898 Silver Bow

System Facility ID:47-05359

Facility Code: 28410
Last Inspected On: 09/22/2020
Operating Permit Renewal Date: 05/22/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Hollow Contracting;William Hollow4067826033

Operator Contact: Susan Lasher

Owner/Operator: Hollow Contracting

Owner/Operator: William J Hollow

Susan Lasher, UST Class A Operator
Susan Lasher, UST Class B Operator

Tank Code	02	Tank Age	22	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4162	Spill Test Date	05/13/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/13/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No

Capacity	15000	ATG Test Date		Line Tightness Test Date	05/13/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/13/2021			ATG Type	Gilbarco-Veeder Root/EMC Basic;Veeder Root/Red Jacket FXID				
Tank Code	03	Tank Age	22	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4163	Spill Test Date	05/13/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/13/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	05/13/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/13/2021			ATG Type	Gilbarco-Veeder Root/EMC Basic;Veeder Root/Red Jacket FXID				
Tank Code	04	Tank Age	22	Tank Installed Date	01/01/2000	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	4164	Spill Test Date	05/13/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	05/13/2021	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	MLLD Line Tightness Testing	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	05/13/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	05/13/2021			ATG Type	Gilbarco-Veeder Root/EMC Basic;Veeder Root/Red Jacket FXID				

Facility Summary in Silver Bow County in the City of Butte

Location: LISACS SOUTHSIDE EXXON
2544 Harrison Ave
Butte, MT 59701 Silver Bow

Facility Code: 28406
Last Inspected On: 08/14/2020
Operating Permit Renewal Date: 08/19/2023

System Facility ID:47-05202

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Edward Lisac

4064947056

Operator Contact: Nadene Lisac

Owner/Operator: Edward G Lisac

Owner/Operator: Edward Lisac

Nadene Lisac, UST Class A Operator

Nadene Lisac, UST Class B Operator

Tank Code	06	Tank Age	32	Tank Installed Date	03/08/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1546	Spill Test Date	03/18/2022	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/14/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	07/05/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/17/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/				
Tank Code	07	Tank Age	32	Tank Installed Date	03/08/1990	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1547	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/14/2020	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date	07/05/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/17/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/				
Tank Code	08	Tank Age	27	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1548	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date	07/07/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/17/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/				
Tank Code	09	Tank Age	27	Tank Installed Date	06/01/1995	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	1549	Spill Test Date		Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5000	ATG Test Date		Line Tightness Test Date	07/04/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	09/17/2020			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/				

Facility Summary in Silver Bow County in the City of Butte

Location: MDOT BUTTE
3751 Wynne Ave
Butte, MT 59701-6712 Silver Bow

System Facility ID:47-01062

Facility Code: 28342
Last Inspected On: 10/26/2021
Operating Permit Renewal Date: 10/26/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: MDOT Helena4064446163

Operator Contact: Jeff Gleason;Joe Radonich;Mike Murolo;Walt Kerttula4064447647

Owner/Operator: MDOT Helena

Charles Stratford, UST Class B Operator
Donald Serich, UST Class B Operator
Jeff Gleason, UST Class A Operator

Joe Radonich, UST Class A Operator
Joe Radonich, UST Class B Global Operator
Mike Murolo, UST Class A Operator
Paul Jordan, UST Class B Operator
Roy Beckman, UST Class B Operator
Walt Kerttula, UST Class A Operator

Tank Code	08	Tank Age	28	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2937	Spill Test Date	10/25/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	10/25/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/25/2021			ATG Type	Gilbarco/EMC Basic				
Tank Code	09	Tank Age	28	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2938	Spill Test Date	10/25/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	10000	ATG Test Date	10/25/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	10/25/2021			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Silver Bow County in the City of Butte

Location: MONTANA RESOURCES INC
600 Shields Ave
Butte, MT 59701-2705 Silver Bow

System Facility ID:47-13549

Facility Code: 28507
Last Inspected On: 11/30/2020
Operating Permit Renewal Date: 03/05/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Montana Resources LLC	4067239542
Operator Contact:	Jeremy Fleege;Thomas Dale	4064988360

Owner/Operator: Montana Resources LLC

Daniel Lorengo, UST Class B Operator
Jeremy Fleege, UST Class A Operator
Jerry Frohreich, UST Class B Operator
Jody D'Arcy, UST Class B Operator
Thomas Dale, UST Class A Operator
Thomas Dale, UST Class B Operator

Tank Code	02	Tank Age	25	Tank Installed Date	10/01/1997	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	High Level Alarm
Tag Number	1687	Spill Test Date	05/03/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	05/03/2021	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Gravity Feed	CP Met Types	Non-corrodible
Product	Oil, Waste	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/ILS-350				

Facility Summary in Silver Bow County in the City of Butte

Location: NORTHWEST PETROLEUM FACILITY
28 Dewey Blvd
Butte, MT 59701-3195 Silver Bow

System Facility ID:56-14033

Facility Code: 30689
Last Inspected On: 04/14/2021
Operating Permit Renewal Date: 08/04/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Northwest Petroleum Co4064976700

Operator Contact: Trent Biggers

Owner/Operator: Northwest Petroleum Co

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	20	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4639	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/08/2020	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	02	Tank Age	20	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4640	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/08/2020	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	03	Tank Age	20	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4641	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/08/2020	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	04	Tank Age	20	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4642	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/08/2020	Catastrophic L.D Type 3.0	Continuous Interstitial Monitoring	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	25000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	05	Tank Age	20	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4643	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	10/08/2020	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	06	Tank Age	20	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4644	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/15/2020	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	07	Tank Age	20	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4645	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/15/2020	Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				

Tank Code	08	Tank Age	20	Tank Installed Date	04/17/2002	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	High Level Alarm
Tag Number	4646	Spill Test Date		Piping Installed Date	09/15/2006	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/15/2020	Catastrophic L.D Type 3.0	Not Required	Piping Type	Gravity Feed	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	25000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				

Facility Summary in Silver Bow County in the City of Butte

Location: RD'S QUICK FUEL
16 E Dewey Blvd
Butte, MT 59701-3195 Silver Bow

System Facility ID:47-13531

Facility Code: 28506
Last Inspected On: 08/10/2022
Operating Permit Renewal Date: 12/05/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: City Service Valcon LLC

Operator Contact: Kary Tonjum 4067554321

Owner/Operator: City Service Valcon LLC

Kary Tonjum, UST Class A Operator
Kary Tonjum, UST Class B Operator
Mitchell Kilmer, UST Class B Operator
Roy Morris, UST Class B Global Operator

Tank Code	01	Tank Age	28	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1712	Spill Test Date	12/08/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	04/13/2021			ATG Type	Franklin Fueling Systems/TS-LS500 E Series;Incon/TS-550 EVO				
Tank Code	02	Tank Age	28	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1713	Spill Test Date	04/13/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2021			ATG Type	Franklin Fueling Systems/TS-LS500 E Series;Incon/TS-550 EVO				
Tank Code	03	Tank Age	28	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1714	Spill Test Date	12/08/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	20000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2021			ATG Type	Franklin Fueling Systems/TS-LS500 E Series;Incon/TS-550 EVO				
Tank Code	04	Tank Age	28	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1715	Spill Test Date	04/13/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	04/13/2021			ATG Type	Franklin Fueling Systems/TS-LS500 E Series;Incon/TS-550 EVO				
Tank Code	05	Tank Age	28	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1716	Spill Test Date	04/13/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2021			ATG Type	Franklin Fueling Systems/TS-LS500 E Series;Incon/TS-550 EVO				
Tank Code	06	Tank Age	28	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1717	Spill Test Date	04/13/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	04/13/2021			ATG Type	Franklin Fueling Systems/TS-LS500 E Series;Incon/TS-550 EVO				
Tank Code	07	Tank Age	28	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	1718	Spill Test Date	04/13/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	05/09/2022	Line Tightness Test Date	08/20/2013	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	04/13/2021			ATG Type	Franklin Fueling Systems/TS-LS500 E Series;Incon/TS-550 EVO				
--	--	--------------------	------------	--	--	----------	---	--	--	--	--

Facility Summary in Silver Bow County in the City of Butte

Location: SILVER BOW COUNTY PUBLIC WORKS
Browns Gulch
Butte, MT 59701 Silver Bow

System Facility ID:47-13157

Facility Code: 28500
Last Inspected On: 03/18/2022
Operating Permit Renewal Date: 06/09/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Silver Bow County Browns Gulch Landfill

4064976521

Operator Contact: Todd Skartved

4064984550

Owner/Operator: Silver Bow County Browns Gulch Landfill

Todd Skartved, UST Class A Operator
Todd Skartved, UST Class B Global Operator

Tank Code	01	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4465	Spill Test Date	08/12/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Not Required	Piping Type	Safe Suction	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection		Vapor Recovery	No
Capacity	12000	ATG Test Date	08/12/2021	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/07/2021			ATG Type	Gilbarco/EMC Basic				

Facility Summary in Silver Bow County in the City of Butte

Location: ST JAMES HEALTHCARE INC
400 S Clark St
Butte, MT 59701-2328 Silver Bow

System Facility ID:47-06924

Facility Code: 28426
Last Inspected On: 09/29/2022
Operating Permit Renewal Date: 12/05/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: St James Healthcare Inc

4067232747

Operator Contact: Keith Walsh;Thomas McKenna

4064171869;4066986391

Owner/Operator: St James Healthcare Inc

James Sullivan, UST Class B Operator
Keith Walsh, UST Class A Operator
Mark McGivern, UST Class B Operator
Thomas McKenna, UST Class A Operator
Thomas McKenna, UST Class B Global Operator

Tank Code	05	Tank Age	21	Tank Installed Date	05/01/2001	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4449	Spill Test Date	11/11/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/11/2021	Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date	09/29/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	11/11/2021			ATG Type	Gilbarco-Veeder Root/TLS-300				

Facility Summary in Silver Bow County in the City of Butte

Location: THREE BEARS ALASKA
45 Three Bears Dr
Butte, MT 59701-7171 Silver Bow

System Facility ID:60-15058

Facility Code: 30832
Last Inspected On: 08/15/2019
Operating Permit Renewal Date: 01/09/2023

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: FIP Master Funding II, LLC

6024485226

Operator Contact: Dave Goody;Lindsay Myers;Wendy Whelchel

4064947547

Owner/Operator: FIP Master Funding II, LLC

Dave Goody, UST Class A Operator
Dave Goody, UST Class B Operator
Lindsay Myers, UST Class A Operator
Lindsay Myers, UST Class B Operator
Matt Dunne, UST Class B Global Operator
Wendy Whelchel, UST Class A Operator

Wendy Whelchel, UST Class B Operator

Tank Code	01	Tank Age	15	Tank Installed Date	04/24/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5103	Spill Test Date		Piping Installed Date	10/25/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	17000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	15	Tank Installed Date	04/24/2007	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	5104	Spill Test Date		Piping Installed Date	10/25/2006	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/22/2020	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 1
3501 Harrison Ave
Butte, MT 59701-3547 Silver Bow

System Facility ID:47-07932

Facility Code: 28433
Last Inspected On: 02/11/2022
Operating Permit Renewal Date: 05/06/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: David Sutey;Sutey Oil Co Inc4064942305

Operator Contact: Jack Hook;Linda Otonicar;Louis Sutey4064915808;4064942305

Owner/Operator: David L Sutey

Owner/Operator: Sutey Oil Co Inc

Cindy Beck, UST Class B Operator
Jack Hook, UST Class A Operator
Jack Hook, UST Class B Global Operator
Jack Hook, UST Class B Operator
James Brown, UST Class B Operator
Linda Otonicar, UST Class A Operator
Louis Sutey, UST Class A Operator
Louis Sutey, UST Class B Global Operator
Shelby Hart, UST Class B Operator

Tank Code	07	Tank Age	32	Tank Installed Date	04/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2062	Spill Test Date	11/30/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Not Listed	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	02/10/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	14783	ATG Test Date	02/10/2022	Line Tightness Test Date	09/09/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8494 Series WPLLD				
Tank Code	08	Tank Age	32	Tank Installed Date	04/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2063	Spill Test Date	11/30/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Not Listed	CP Met Types	
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	02/10/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	02/10/2022	Line Tightness Test Date	08/30/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8494 Series WPLLD				
Tank Code	09	Tank Age	32	Tank Installed Date	04/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2064	Spill Test Date	11/30/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Not Listed	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	02/10/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	02/10/2022	Line Tightness Test Date	08/28/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8494 Series WPLLD				
Tank Code	10	Tank Age	32	Tank Installed Date	04/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2065	Spill Test Date	11/30/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Not Listed	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	02/10/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5929	ATG Test Date	02/10/2022	Line Tightness Test Date	09/05/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8494 Series WPLLD				
Tank Code	11	Tank Age	32	Tank Installed Date	04/10/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2066	Spill Test Date	11/30/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Not Listed	CP Met Types	
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date	02/10/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	5929	ATG Test Date	02/10/2022	Line Tightness Test Date	09/19/2021	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8494 Series WPLLD				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 16
4701 Harrison Ave
Butte, MT 59701-7002 Silver Bow

Facility Code: 28486
Last Inspected On: 06/28/2022
System Facility ID:47-10657
Operating Permit Renewal Date: 07/10/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Sutey Oil Co Inc	4064942305
Operator Contact:	Linda Otonicar;Louis Sutey	4064915808;4064942305

Owner/Operator: Sutey Oil Co Inc

Geoff Gifford, UST Class B Operator
Linda Otonicar, UST Class A Operator
Louis Sutey, UST Class A Operator

Tank Code	01	Tank Age	35	Tank Installed Date	11/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1921	Spill Test Date	03/18/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/28/2022	Tank/Piping CP Test Date	06/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/28/2022	Line Tightness Test Date	02/10/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8494 Series WPLLD				
Tank Code	02	Tank Age	35	Tank Installed Date	11/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1922	Spill Test Date	03/18/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/28/2022	Tank/Piping CP Test Date	06/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/28/2022	Line Tightness Test Date	02/11/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	06/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8494 Series WPLLD				
Tank Code	03	Tank Age	35	Tank Installed Date	11/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1923	Spill Test Date	03/18/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	06/28/2022	Tank/Piping CP Test Date	06/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/28/2022	Line Tightness Test Date	02/11/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8494 Series WPLLD				
Tank Code	04	Tank Age	35	Tank Installed Date	11/01/1987	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	1924	Spill Test Date	03/18/2022	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Diesel	PLLD Test Date	06/28/2022	Tank/Piping CP Test Date	06/14/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/28/2022	Line Tightness Test Date	02/12/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	06/28/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8494 Series WPLLD				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 2
1900 S Montana St
Butte, MT 59701-3023 Silver Bow

System Facility ID:47-07935

Facility Code: 28436
Last Inspected On: 06/13/2022
Operating Permit Renewal Date: 06/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Sutey Oil Co Inc

4064942305

Operator Contact: Jack Hook;Linda Otonicar;Louis Sutey

4064915808;4064942305

Owner/Operator: Sutey Oil Co Inc

Jack Hook, UST Class A Operator
Jessica Willis, UST Class B Global Operator
Linda Otonicar, UST Class A Operator
Louis Sutey, UST Class A Operator
Louis Sutey, UST Class B Global Operator

Tank Code	04	Tank Age	33	Tank Installed Date	05/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2070	Spill Test Date	02/10/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	06/13/2022	Tank/Piping CP Test Date	06/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	06/30/2022	Line Tightness Test Date	04/15/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	05	Tank Age	33	Tank Installed Date	05/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2071	Spill Test Date	02/10/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	06/13/2022	Tank/Piping CP Test Date	06/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	06/30/2022	Line Tightness Test Date	04/15/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	06	Tank Age	33	Tank Installed Date	05/15/1989	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve

Tag Number	2072	Spill Test Date	02/10/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	06/13/2022	Tank/Piping CP Test Date	06/29/2022	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	06/30/2022	Line Tightness Test Date	04/15/2019	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 4 2610 Harrison Ave Butte, MT 59701 Silver Bow	System Facility ID:47-07934	Facility Code: 28435 Last Inspected On: 04/26/2022 Operating Permit Renewal Date: 06/20/2025
Note: Inspection is due 90 days before the Operating Permit Renewal Date.		

Owner Operator Contact:	David Sutey;Sutey Oil Co Inc	4064942305
-------------------------	------------------------------	------------

Operator Contact:	Geoff Gifford;Jack Hook;Linda Otonicar;Louis Sutey	4064915808;4064942305;4064943155
-------------------	--	----------------------------------

Owner/Operator: David L Sutey

Owner/Operator: Sutey Oil Co Inc

Geoff Gifford, UST Class A Operator
Jack Hook, UST Class A Operator
Kasey Maes, UST Class B Operator
Linda Otonicar, UST Class A Operator
Linda Otonicar, UST Class B Global Operator
Louis Sutey, UST Class A Operator
Louis Sutey, UST Class B Global Operator

Tank Code	05	Tank Age	32	Tank Installed Date	03/13/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2067	Spill Test Date	12/01/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible

Product	Gasoline	PLLD Test Date	04/26/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	04/26/2022	Line Tightness Test Date	01/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/18/2022			ATG Type	Veeder Root/8484 Series PLLD;Veeder Root/TLS-350				
Tank Code	06	Tank Age	32	Tank Installed Date	03/13/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2068	Spill Test Date	12/01/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/26/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	04/26/2022	Line Tightness Test Date	01/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/18/2022			ATG Type	Veeder Root/8484 Series PLLD;Veeder Root/TLS-350				
Tank Code	07	Tank Age	32	Tank Installed Date	03/13/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2069	Spill Test Date	12/01/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	04/15/2019	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/26/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	ELLD 0.2	Vapor Recovery	No
Capacity	11627	ATG Test Date	04/26/2022	Line Tightness Test Date	01/25/2022	Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/18/2022			ATG Type	Veeder Root/8484 Series PLLD;Veeder Root/TLS-350				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 5
901 E Front St
Butte, MT 59701-2929 Silver Bow

System Facility ID:47-00942

Facility Code: 28334
Last Inspected On: 04/07/2022
Operating Permit Renewal Date: 06/12/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: David Sutey;Sutey Oil Co Inc4064942305

Owner/Operator: David L Sutey

Owner/Operator: Sutey Oil Co Inc

- Allen Beagley, UST Class B Global Operator
- Allen Beagley, UST Class B Operator
- Jack Hook, UST Class A Operator
- Jack Hook, UST Class B Global Operator
- Jack Hook, UST Class B Operator
- Kenneth Beck, UST Class B Global Operator
- Linda Otonicar, UST Class A Operator
- Linda Otonicar, UST Class B Operator
- Louis Sutey, UST Class A Operator
- Louis Sutey, UST Class B Global Operator
- Robert Osmanson, UST Class B Operator

Tank Code	05	Tank Age	28	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2059	Spill Test Date	02/11/2022	Piping Installed Date	11/07/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	02/11/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/11/2022	Line Tightness Test Date	08/16/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	03/18/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	06	Tank Age	28	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2060	Spill Test Date	02/11/2022	Piping Installed Date	11/07/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Diesel	PLLD Test Date	02/11/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/11/2022	Line Tightness Test Date	11/18/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No

		Overfill Test Date	03/18/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	07	Tank Age	28	Tank Installed Date	08/01/1994	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	2061	Spill Test Date	02/11/2022	Piping Installed Date	11/07/2016	Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/01/2016	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	
Product	Gasoline	PLLD Test Date	02/11/2022	Tank/Piping CP Test Date		Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	12000	ATG Test Date	02/11/2022	Line Tightness Test Date	08/20/2021	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	03/18/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: THRIFTWAY SUPER STOP 6
2401 Continental Dr
Butte, MT 59701-6562 Silver Bow

System Facility ID:47-07936

Facility Code: 28437
Last Inspected On: 01/10/2022
Operating Permit Renewal Date: 02/27/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: David Sutey;Sutey Oil Co Inc4064942305

Operator Contact: Jack Hook;Ken Beck;Linda Otonicar;Louis Sutey4064915808;4064942305;4067232022

Owner/Operator: David L Sutey

Owner/Operator: Sutey Oil Co Inc

- Dean Brown, UST Class B Operator
- Jack Hook, UST Class A Operator
- Jack Hook, UST Class B Global Operator
- Jack Hook, UST Class B Operator
- Jessica Willis, UST Class B Global Operator
- Ken Beck, UST Class A Operator
- Ken Beck, UST Class B Operator
- Linda Otonicar, UST Class A Operator
- Louis Sutey, UST Class A Operator
- Louis Sutey, UST Class B Global Operator

Tank Code	01	Tank Age	54	Tank Installed Date	05/07/1968	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2073	Spill Test Date	11/18/2021	Piping Installed Date	06/23/2014	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/23/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	11/17/2021	Tank/Piping CP Test Date	04/16/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/18/2021	Line Tightness Test Date	01/17/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/17/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	02	Tank Age	54	Tank Installed Date	05/07/1968	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2074	Spill Test Date	11/18/2021	Piping Installed Date	06/23/2014	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/23/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	11/17/2021	Tank/Piping CP Test Date	04/16/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	11/18/2021	Line Tightness Test Date	01/21/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/17/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				
Tank Code	03	Tank Age	49	Tank Installed Date	05/07/1973	Tank Material	Bare Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2075	Spill Test Date	11/18/2021	Piping Installed Date	06/23/2014	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	07/23/2014	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	11/17/2021	Tank/Piping CP Test Date	04/16/2019	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	11/18/2021	Line Tightness Test Date	01/19/2019	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	11/17/2021			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP BUTTE #5
2305 Continental Dr
Butte, MT 59701 Silver Bow

Facility Code: 30912
Last Inspected On: 08/19/2022
System Facility ID:60-15187
Operating Permit Renewal Date: 06/11/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte 5 Town Pump LLC;Town Pump Inc Northwest Missoula 4064976700

Operator Contact: Trent Biggers

Owner/Operator: Butte 5 Town Pump LLC

Owner/Operator: Town Pump Inc Northwest Missoula

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	11	Tank Installed Date	11/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5310	Spill Test Date		Piping Installed Date	07/28/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	20000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	11	Tank Installed Date	11/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5311	Spill Test Date		Piping Installed Date	07/28/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	11	Tank Installed Date	11/01/2011	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5312	Spill Test Date		Piping Installed Date	07/28/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 1
1370 Harrison Ave
Butte, MT 59701-4848 Silver Bow

Facility Code: 28450
Last Inspected On: 08/29/2022
System Facility ID:47-08679
Operating Permit Renewal Date: 09/19/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte 1 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Butte 1 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	05	Tank Age	34	Tank Installed Date	04/11/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2618	Spill Test Date	04/28/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/25/2022	Tank/Piping CP Test Date	04/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/09/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	04/28/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				
Tank Code	06	Tank Age	36	Tank Installed Date	04/11/1986	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2619	Spill Test Date	04/28/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/25/2022	Tank/Piping CP Test Date	04/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/09/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/28/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				
Tank Code	07	Tank Age	34	Tank Installed Date	04/11/1988	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2620	Spill Test Date	04/28/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	07/25/2022	Tank/Piping CP Test Date	04/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/09/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/28/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				
Tank Code	08	Tank Age	31	Tank Installed Date	07/28/1991	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	2621	Spill Test Date	04/28/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	07/25/2022	Tank/Piping CP Test Date	04/27/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	4000	ATG Test Date	06/09/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	04/28/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 10
901 N Excelsior Ave
Butte, MT 59701 Silver Bow

System Facility ID:47-08687

Facility Code: 28458
Last Inspected On: 09/11/2020
Operating Permit Renewal Date: 02/09/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Butte 10 Town Pump LLC	4064976700
Operator Contact:	Trent Biggers	

Owner/Operator: Butte 10 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	51	Tank Installed Date	04/12/1971	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2633	Spill Test Date	07/13/2021	Piping Installed Date	11/01/2019	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/30/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/08/2020	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/13/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	02	Tank Age	51	Tank Installed Date	04/12/1971	Tank Material	Cathodically Protected Steel	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	2634	Spill Test Date	07/13/2021	Piping Installed Date	11/01/2019	Tank Construction	Lined Interior/Impressed Current	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	04/30/2019	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date	08/08/2020	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No

Capacity	4000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	No
		Overfill Test Date	07/13/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 2
531 S Montana St
Butte, MT 59701 Silver Bow

System Facility ID:47-08680

Facility Code: 28451
Last Inspected On: 08/22/2022
Operating Permit Renewal Date: 10/09/2024

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte 2 Town Pump LLC 4064976700

Operator Contact: Trent Biggers

Owner/Operator: Butte 2 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	04	Tank Age	1	Tank Installed Date	03/31/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6038	Spill Test Date	03/19/2021	Piping Installed Date	03/31/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/19/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/12/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	24000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	03/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/8590 Series DPLLD				
Tank Code	05	Tank Age	1	Tank Installed Date	03/31/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	6039	Spill Test Date	03/19/2021	Piping Installed Date	03/31/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/19/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	04/12/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	03/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/8590 Series DPLLD				
Tank Code	06	Tank Age	1	Tank Installed Date	03/31/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	6040	Spill Test Date	03/19/2021	Piping Installed Date	03/31/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/19/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date	03/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS				
Tank Code	07	Tank Age	1	Tank Installed Date	03/31/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6041	Spill Test Date	03/19/2021	Piping Installed Date	03/31/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/19/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	04/12/2021	Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	03/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/8590 Series DPLLD				
Tank Code	08	Tank Age	1	Tank Installed Date	03/31/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6042	Spill Test Date	03/19/2021	Piping Installed Date	03/31/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/19/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	15000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	03/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/8590 Series DPLLD				
Tank Code	09	Tank Age	1	Tank Installed Date	03/31/2021	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	6043	Spill Test Date	03/19/2021	Piping Installed Date	03/31/2021	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	03/19/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel, Dyed	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	03/19/2021			ATG Type	Gilbarco-Veeder Root/TLS-450PLUS;Veeder Root/8590 Series DPLLD				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 3
2328 S Montana St
Butte, MT 59701 Silver Bow

Facility Code: 28453
Last Inspected On: 07/22/2022
System Facility ID:47-08682
Operating Permit Renewal Date: 07/27/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Butte 3 Town Pump LLC4064976700

Operator Contact: Trent Biggers

Owner/Operator: Butte 3 Town Pump LLC

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	41	Tank Installed Date	04/11/1981	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2625	Spill Test Date	09/21/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Galvanic
Product	Gasoline	PLLD Test Date	05/22/2022	Tank/Piping CP Test Date	07/01/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/22/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	09/21/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				
Tank Code	04	Tank Age	32	Tank Installed Date	10/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2626	Spill Test Date	09/21/2022	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/22/2022	Tank/Piping CP Test Date	05/05/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/22/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	09/21/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				
Tank Code	05	Tank Age	32	Tank Installed Date	10/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2627	Spill Test Date	07/14/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date	05/22/2022	Tank/Piping CP Test Date	05/05/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/22/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	07/14/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				
Tank Code	06	Tank Age	32	Tank Installed Date	10/01/1990	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	2628	Spill Test Date	07/14/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date	05/22/2022	Tank/Piping CP Test Date	05/05/2012	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	05/22/2022	Line Tightness Test Date		Secondary Tank Leak Detection	Approved Remote Monitoring	Secondary Pipe Detection	Approved Remote Monitoring	Energy Act	No
		Overfill Test Date	07/14/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 4 3700 Harrison Ave Butte, MT 59701 Silver Bow	System Facility ID:56-13911	Facility Code: 30581 Last Inspected On: 08/29/2022 Operating Permit Renewal Date: 10/14/2024
Note: Inspection is due 90 days before the Operating Permit Renewal Date.		

Owner Operator Contact: Butte 4 Town Pump LLC	4064976700
---	------------

Operator Contact: Trent Biggers

Owner/Operator: Butte 4 Town Pump LLC

Trent Biggers, UST Class A Operator Trent Biggers, UST Class B Global Operator											
Tank Code	01	Tank Age	23	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4022	Spill Test Date	06/01/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/29/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	02	Tank Age	23	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve

Tag Number	4023	Spill Test Date	04/26/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date	06/29/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/29/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	03	Tank Age	23	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4024	Spill Test Date	06/01/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	15000	ATG Test Date	06/29/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	04	Tank Age	23	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4025	Spill Test Date	06/01/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date	06/29/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	02/11/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				

Tank Code	05	Tank Age	23	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Flapper Valve
Tag Number	4026	Spill Test Date	06/01/2022	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/29/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/01/2022			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				
Tank Code	06	Tank Age	23	Tank Installed Date	04/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Flexible Plastic	Overfill Types	Ball Float Valve
Tag Number	4294	Spill Test Date	04/26/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	06/19/2018	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	6000	ATG Test Date	06/29/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date	06/29/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8484 Series PLLD				

Facility Summary in Silver Bow County in the City of Butte

Location: TOWN PUMP INC BUTTE 8
2001 Dewey Blvd
Butte, MT 59701 Silver Bow

System Facility ID:47-08686

Facility Code: 28457
Last Inspected On: 10/20/2022
Operating Permit Renewal Date: 10/20/2025

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Butte 8 Town Pump LLC	4064976700
Operator Contact:	Trent Biggers	

Owner/Operator: Butte 8 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	41	Tank Installed Date	10/01/1981	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2629	Spill Test Date	07/20/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/10/2022	Tank/Piping CP Test Date	05/03/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	30000	ATG Test Date	08/10/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/20/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8494 Series WPLLD				
Tank Code	03	Tank Age	45	Tank Installed Date	01/01/1977	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2631	Spill Test Date	07/20/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	10/20/2022	Tank/Piping CP Test Date	05/03/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/10/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/20/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8494 Series WPLLD				
Tank Code	04	Tank Age	41	Tank Installed Date	10/01/1981	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	2632	Spill Test Date	07/20/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/10/2022	Tank/Piping CP Test Date	05/03/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date	08/10/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date	07/20/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8494 Series WPLLD				
Tank Code	02	Tank Age	41	Tank Installed Date	10/01/1981	Tank Material	Cathodically Protected Steel	Piping Material	Steel	Overfill Types	Flapper Valve
Tag Number	4265	Spill Test Date	07/20/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	10/20/2022	Tank/Piping CP Test Date	05/03/2021	Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	30000	ATG Test Date	08/10/2022	Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date	07/20/2021			ATG Type	Gilbarco-Veeder Root/TLS-350;Veeder Root/8494 Series WPLLD				

Facility Summary in Silver Bow County in the City of Melrose

Location: MELROSE BAR 120 Main St Melrose, MT 59743 Silver Bow	System Facility ID:47-07486	Facility Code: 28431 Last Inspected On: 02/03/2021 Operating Permit Renewal Date: 03/03/2024
Note: Inspection is due 90 days before the Operating Permit Renewal Date.		

Owner Operator Contact: Melrose License Holdings LLC;Rebecca Mergenthaler 4067993577

Operator Contact: Lee Lively;Rebecca Mergenthaler 4067993577

Owner/Operator: Melrose License Holdings LLC

Owner/Operator: Rebecca Mergenthaler
Lee Lively, UST Class A Operator
Lee Lively, UST Class B Operator
Rebecca Mergenthaler, UST Class A Operator
Rebecca Mergenthaler, UST Class B Operator

Tank Code	01	Tank Age	39	Tank Installed Date	05/08/1983	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
-----------	----	----------	----	---------------------	------------	---------------	------------------------------	-----------------	-------------------------------	----------------	---------------

Tag Number	4054	Spill Test Date	11/09/2021	Piping Installed Date	08/16/2011	Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/09/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Gasoline	PLLD Test Date	08/18/2022	Tank/Piping CP Test Date	02/03/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	10000	ATG Test Date	08/18/2022	Line Tightness Test Date	10/06/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				
Tank Code	02	Tank Age	39	Tank Installed Date	05/08/1983	Tank Material	Cathodically Protected Steel	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	4055	Spill Test Date	11/09/2021	Piping Installed Date	08/16/2011	Tank Construction	Lined Interior/Impressed Current	Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date	11/09/2021	Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Impressed Current
Product	Diesel	PLLD Test Date	08/18/2022	Tank/Piping CP Test Date	02/03/2021	Primary Tank Leak Detection	Automatic Tank Gauging 0.2	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	6000	ATG Test Date	08/18/2022	Line Tightness Test Date	10/06/2020	Secondary Tank Leak Detection		Secondary Pipe Detection	ELLD 0.2	Energy Act	No
		Overfill Test Date	02/10/2022			ATG Type	Gilbarco-Veeder Root/TLS-350/Gilbarco EMC;Veeder Root/8484 Series PLLD				

Facility Summary in Silver Bow County in the City of Rocker

Location: ROCKER FLYING J 122000 N Browns Gulch Rd Rocker, MT 59701 Silver Bow	System Facility ID:47-09893	Facility Code: 28472 Last Inspected On: 11/02/2020 Operating Permit Renewal Date: 02/09/2024
--	-----------------------------	--

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact: Rocker 3 Town Pump LLC	4064976700
--	------------

Operator Contact: Trent Biggers

Owner/Operator: Rocker 3 Town Pump LLC

Trent Biggers, UST Class A Operator

Trent Biggers, UST Class B Global Operator

Tank Code	15	Tank Age	10	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5302	Spill Test Date	07/21/2021	Piping Installed Date	04/12/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	07/21/2021	Line Tightness Test Date	09/06/2014	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	16	Tank Age	10	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5303	Spill Test Date	07/21/2021	Piping Installed Date	08/26/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	07/21/2021	Line Tightness Test Date	09/06/2014	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	17	Tank Age	10	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5304	Spill Test Date	07/21/2021	Piping Installed Date	08/26/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	30000	ATG Test Date	07/21/2021	Line Tightness Test Date	09/06/2014	Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes

		Overfill Test Date	07/21/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	18	Tank Age	10	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5305	Spill Test Date	07/21/2021	Piping Installed Date	08/26/2014	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	30000	ATG Test Date	07/21/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	19	Tank Age	10	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve
Tag Number	5306	Spill Test Date	07/21/2021	Piping Installed Date	07/25/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/21/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	20	Tank Age	10	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Flapper Valve
Tag Number	5307	Spill Test Date	07/21/2021	Piping Installed Date	07/25/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	Yes
Capacity	15000	ATG Test Date	07/21/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	21	Tank Age	10	Tank Installed Date	04/12/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve;Flapper Valve

Tag Number	5308	Spill Test Date	07/21/2021	Piping Installed Date	07/25/2011	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Continuous Interstitial Monitoring	Primary Pipe Detection	Continuous Interstitial Monitoring	Vapor Recovery	No
Capacity	8000	ATG Test Date	07/21/2021	Line Tightness Test Date		Secondary Tank Leak Detection	Statistical Inventory Reconciliation	Secondary Pipe Detection	Statistical Inventory Reconciliation	Energy Act	Yes
		Overfill Test Date	07/21/2021			ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	23	Tank Age	0	Tank Installed Date		Tank Material	Fiberglass Reinforced Plastic	Piping Material	Unknown	Overfill Types	
Tag Number	5364	Spill Test Date		Piping Installed Date	07/25/2011	Tank Construction	Double-Walled	Piping Construction	None	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0		Piping Type	Not Listed	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Not Listed	Primary Pipe Detection	Not Listed	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type					

Facility Summary in Silver Bow County in the City of Rocker

Location:	TOWN PUMP INC ROCKER 1000 Grizzly Trl Rocker, MT 59701-9646 Silver Bow	Facility Code:	28501
		Last Inspected On:	08/30/2022
		Operating Permit Renewal Date:	05/31/2024
		System Facility ID:	47-13173

Note: Inspection is due 90 days before the Operating Permit Renewal Date.

Owner Operator Contact:	Rocker 1 Town Pump LLC	4064976700
-------------------------	------------------------	------------

Operator Contact:	Trent Biggers
-------------------	---------------

Owner/Operator:	Rocker 1 Town Pump LLC
-----------------	------------------------

Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Code	01	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2635	Spill Test Date	09/09/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No

Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	02	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2636	Spill Test Date	09/09/2021	Piping Installed Date		Tank Construction		Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/25/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	03	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2637	Spill Test Date	09/09/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/25/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Gasoline	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	04	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2638	Spill Test Date	09/09/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/25/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No

Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	05	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2639	Spill Test Date	09/09/2021	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/25/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	06	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2640	Spill Test Date	09/09/2021	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/25/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	12000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	07	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2641	Spill Test Date	09/09/2021	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Electronic Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	08	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2642	Spill Test Date	09/09/2021	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No

Tank Status	Currently in Use	MLLD Test Date	02/25/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-450				
Tank Code	09	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2643	Spill Test Date	09/09/2021	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/25/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	10	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2644	Spill Test Date	09/09/2021	Piping Installed Date	09/14/2006	Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/25/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	11	Tank Age	29	Tank Installed Date	06/01/1993	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	2645	Spill Test Date	09/09/2021	Piping Installed Date		Tank Construction		Piping Construction	None	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/25/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	No

		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	12	Tank Age	23	Tank Installed Date	06/01/1999	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	Ball Float Valve
Tag Number	4103	Spill Test Date	09/09/2021	Piping Installed Date		Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Currently in Use	MLLD Test Date	02/25/2020	Sump Tightness Test Date		Catastrophic L.D Type 3.0	Mechanical Line Leak Detector	Piping Type	Pressurized	CP Met Types	Non-corrodible
Product	Diesel	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Statistical Inventory Reconciliation	Primary Pipe Detection	Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	8000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection	Continuous Interstitial Monitoring	Secondary Pipe Detection	Continuous Interstitial Monitoring	Energy Act	No
		Overfill Test Date				ATG Type	Gilbarco-Veeder Root/TLS-350				
Tank Code	13	Tank Age	10	Tank Installed Date	11/01/2012	Tank Material	Fiberglass Reinforced Plastic	Piping Material	Fiberglass Reinforced Plastic	Overfill Types	
Tag Number	5375	Spill Test Date		Piping Installed Date	05/07/2012	Tank Construction	Double-Walled	Piping Construction	Double Walled	AST	No
Tank Status	Other	MLLD Test Date		Sump Tightness Test Date		Catastrophic L.D Type 3.0	Auto Dialer	Piping Type	Pressurized	CP Met Types	
Product	DEF (Not Regulated)	PLLD Test Date		Tank/Piping CP Test Date		Primary Tank Leak Detection	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Primary Pipe Detection	Approved Remote Monitoring;Continuous Interstitial Monitoring;Statistical Inventory Reconciliation	Vapor Recovery	No
Capacity	10000	ATG Test Date		Line Tightness Test Date		Secondary Tank Leak Detection		Secondary Pipe Detection		Energy Act	Yes
		Overfill Test Date				ATG Type					